

## HEATING MODE

Model	: PERS.095G
Outdoor side heat exchanger	: Air
Indoor side heat exchanger	: Air
Type	: Compressor driven vapour compression
Driver of the compressor	: Electric Motor

Rated heating capacity [kW] - $P_{rated,h}$	57,89
Seasonal space heating energy efficiency [%] - $\eta_{s,h}$	134,0
Seasonal coefficient of performance - SCOP	3,43
Sound power level, outdoor [dB] - $L_{WA}$	81

Declared heating capacity for part load at given outdoor temperatures $T_j$ and indoor 20°C (Dry bulb)		
Pdh		
	Value	Unit
$T_j = -7\text{ °C}$	40,42	[kW]
$T_j = +2\text{ °C}$	33,16	[kW]
$T_j = +7\text{ °C}$	26,30	[kW]
$T_j = +12\text{ °C}$	29,80	[kW]
$T_j = T_{biv}\text{ °C}$	44,25	[kW]
$T_j = T_{ol}\text{ °C}$	37,37	[kW]
If $TOL < -20\text{ °C}$ , $T_j = -15\text{ °C}$ (for air-to-water (brine) heat pumps)	-	[kW]

Declared efficiency of performance for part load at given outdoor temperature $T_j$ and indoor 20°C (Dry bulb)		
COP <sub>d</sub>		
	Value	Unit
$T_j = -7\text{ °C}$	2,80	[kW]
$T_j = +2\text{ °C}$	3,78	[kW]
$T_j = +7\text{ °C}$	4,41	[kW]
$T_j = +12\text{ °C}$	4,94	[kW]
$T_j = T_{biv}\text{ °C}$	2,92	[kW]
$T_j = T_{ol}\text{ °C}$	2,66	[kW]
If $TOL < -20\text{ °C}$ , $T_j = -15\text{ °C}$ (for air-to-water (brine) heat pumps)	-	[kW]

Bivalent temperature	$T_{biv}$	-2	°C
Degradation coefficient, for each part load condition where it is relevant <sup>1</sup>	$Cd_h$	0,25	

Power input in modes other than active mode								
Off mode	[kW]	P <sub>OFF</sub>	0,00		Crankcase heater mode	[kW]	P <sub>CK</sub>	0,18
Thermostat-off mode	[kW]	P <sub>TO</sub>	0,02		Standby mode	[kW]	P <sub>SB</sub>	0,04
Supplementary heater					Heating capacity	[kW]	elbu	23,30
					Type of energy input		Electric	
Capacity control					Staged			
GWP of the refrigerant, kg CO <sub>2</sub> eq [100 years]					2088			
For air-to-air air conditioner: air flow rate, outdoor measured [m <sup>3</sup> /h]					23819			

İmbat Soğutma Isıtma Makina Sanayi ve Ticaret A.Ş
KOSBİ Mh, 62. Sk. no:14, 35371 Kemalpaşa/İzmir
Pbx: +90 232 877 21 01
<a href="http://www.imbat.com">www.imbat.com</a>

<sup>1</sup> If  $Cd_h$  is not determined by measurement then the default degradation coefficient air conditioners shall be 0,25.